

## Hannen Lake Park Shop Building Addendum #2



**Date:** February 8, 2023

**To:** All Contractors Bidding

**Project:** HANNEN LAKE PARK SHOP BUILDING PROJECT # BCC012023

**Bid Date:** Bids Received by Monday, February 13<sup>th</sup> at 2:00pm local time

---

### To Whom it May Concern:

Please make the following corrections or changes to the bidding documents. These items shall supersede, modify and/or change all statements or drawings to the contrary in the plans and specifications and shall take precedence over these documents. Bidders shall base their bid on the plans and specifications as modified by the changes herein specified.

---

### Clarifications:

#### Item #1: Regarding Bid Package #7 Electrical

- Restrooms: One LED light and one Exhaust Fan/LED light combo in the public restrooms. One Exhaust Fan/LED light combo in the shop restroom. Hand dryer units only are owner provided, roughed in by contractor.
- Sewage Treatment: See drawings. Sewage pump is 75' from the building. Will require two 120V circuits: a 15 amp for alarm float and 20 amp for the pump.
- Fuel Pumps: See drawings. 50' from the building two 120V pumps.
- Exterior Lighting: See drawings. LED pack lights.
- Emergency Exit Lighting: See drawings. Emergency/exit lights units only provided by the owner, roughed in by contractor.
- Fans: See drawings. Fans are 72" 120V, brand TBD.